



Government of Telangana
HYDERABAD DISASTER RESPONSE AND ASSET PROTECTION AGENCY
Renewal Fire No Objection Certificate



From: The Commissioner, Hyderabad Disaster Response and Asset Protection Agency (HYDRAA)	To: Renuka Butta,	
--	-----------------------------	---

Acknowledgement No. HYDRAA0001592026, Dated: 02-09-2026

Sir,

Sub: HYDRAA – Disaster Management Wing - Issuance of Renewal Fire No Objection Certificate for the existing Non High-Rise Building consisting of Cellar + Ground + 4 Upper Floors at Meridian School, 8-2-541, Road Number 7, Zahara Nagar, Banjara Hills, Hyderabad, Telangana, PIN 500034, India, belongs to Renuka Butta – Regarding.

* * * * *

Ref:

1. Proceedings Rc.No. 5041/B2/97, Dated: 12.03.2010 of the Director General of the State Disaster Response and Fire Services Department, Andhra Pradesh, Hyderabad.
2. Proceedings No. DM/0011/2018/D(VK) EVDM/2018, dt.29.06.2018 of the Commissioner, GHMC.
3. G.O.Ms.No.99, MA&UD, (GHMC.I) Department, Dt: 19.07.2024.
4. Application of the Management, received through Acknowledgement No. HYDRAA0001592026, dt: 20-08-2026.
5. Vide reference 5th cited, the team has inspected the site, scrutinized the plans for the Issuance of Renewal Fire No Objection Certificate for the existing Non High-Rise Building consisting of Cellar + Ground + 4 Upper Floors at Meridian School, 8-2-541, Road Number 7, Zahara Nagar, Banjara Hills, Hyderabad, Telangana, PIN 500034, India, belongs to Renuka Butta and recommended for the Issuance of Renewal Fire No Objection Certificate

1. APPLICANT DETAILS :

1	Name of the Owner	Renuka Butta
2	Father's Name	D Madhusudan
3	Email	admin.bjr@meridianschool.in
4	Mobile Number	9133474602

2. BUILDING PARTICULARS :

1	Name & Address of the Building	Meridian School, 8-2-541, Road Number 7, Zahara Nagar, Banjara Hills, Hyderabad, Telangana, PIN 500034, India
2	Plot Area (Sq.M)	6302
3	Building Height (M)	14.95
4	Abutting Road Width(M)	24
5	No. of Floors	Cellar + Ground Floor + 4 Upper Floors
6	Commissionerate	GHMC Municipal Corporation
7	Zone	Khairatabad



Principal
Meridian School for Boys and Girls
C.B.S.E. Aff. No.3630044
Road No.7 Banjara Hills, Hyderabad-34.

8	Circle	36 - Jubilee Hills
9	Ward	215 - Jubilee Hills

3. OPEN SPACES ALL AROUND THE BUILDING AS PER ISSUED NOC IN THE YEAR 2013

Sl.No	Direction	Required (M)	Provided (M)	Deficit (M)	Remarks
1	Front	6	10	0	-
2	Side I	6	1.35	4.65	-
3	Side II	6	2	4	-
4	Rear	6	3	3	-

4. FLOOR-WISE DETAILS :

SLNo	Floor	Area (Sq.M)	Type of Occupancy	Occupancy Description	Max Occupant Load
1	Cellar	1907.16	Parking	Parking	
2	Ground Floor	1538.80	Educational (B)	Schools up to senior secondary level (B1)	385
3	First Floor	1538.80	Educational (B)	Schools up to senior secondary level (B1)	385
4	Second Floor	1538.80	Educational (B)	Schools up to senior secondary level (B1)	385
5	Third Floor	1538.80	Educational (B)	Schools up to senior secondary level (B1)	385
6	Fourth Floor	1538.80	Educational (B)	Schools up to senior secondary level (B1)	385
Total		9,601.16			1925

5. MEANS OF ESCAPE :

SLNo	Type of Staircase	Number of Staircases	Width of Staircase (M)	Remarks
1	Internal Staircase	2	1.6	-
2	External Staircase	1	1.45	-
Total			4.65	

6. FIRE SAFETY INSTALLATION AS PER N.B.C - 2005 :

SLNo	Fire Safety Installation	Required	Provided	Deficit	Remarks
1	Fire Extinguishers	50	50	0	-
2	First Aid Hose Reel	12	12	0	-
3	Wet Riser	0	0	0	-
4	Yard Hydrant	0	0	0	-
5	Automatic Sprinkler System	90	90	0	-



Principal
Meridian School for Boys and Girls
C.B.S.E Aff. No. 3630044
Road No. 7 Banjara Hills, Hyderabad-34.

Sl.No	Fire Safety Installation	Required	Provided	Deficit	Remarks
6	Manually Operated Electronic Fire Alarm Systems	12	12	0	-
7	Automatic Detection and Alarm System	0	0	0	-
8	Under-ground Static Water Storage Tank Combined Capacity for Wet Riser, Yard Hydrant and Sprinklers per Set of Pumps in Litres	0	0	0	-
9	Capacity of Terrace Tank over Respective Tower Terrace in Litres	15000	15000	0	-
10	Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM ²	900	900	0	-
11	Number of Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Remotest Location (Electrical)	0	0	0	-
12	Capacity of Electrical Pump in LPM	0	0	0	-
13	Number of Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Remotest Location (Diesel)	0	0	0	-
14	Capacity of Diesel Pump in LPM	0	0	0	-
15	Number of Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm ² at Remotest Location (Electrical/Jockey)	0	0	0	-
16	Capacity of Electrical (Jockey) Pump in LPM	0	0	0	-
17	No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/CM ²	1	1	0	-
18	Down Comer	2	2	0	-

7. TERMS & CONDITIONS :


1. The Renewal of Fire NOC issued is confined to the Fire Safety measures installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use / Occupancy or Building Regularization. The Owner / Occupier shall comply the Building Rules / Govt. Orders as applicable.



Principal
Meridian School for Boys and Girls
C.B.S.E. Aff. No.3630044
Road No. 7, Banjara Hills, Hyderabad-34

2. Fixed and first-aid Fire Fighting equipment, alarm etc shall be tested and maintained regularly as per applicable standards and Fire-Drills conducted quarterly for first two years and half yearly after two Years. Also expired equipment should be replaced immediately.
3. Emergency power generator etc., and associated equipment should be tested periodically, verified as per NBC, and IS-1646.
4. Adequate ventilation should be provided in all floors of the building.
5. Evacuation plan showing exit routes and recommended action plan shall be displayed at conspicuous locations and shall be exhibited at all times. All escape / exit routes shall not be blocked or encroached.
6. Fresh NOC would be required for any change in occupancy or additions/alterations in the building structure as per NBC of India and building bye/laws.
7. The Management has to maintain Fire Safety Measures at all times in good working condition as seen during the inspection.
8. Any Loss of life or property due to Non-functioning of Fire Safety Measures and other installations shall be the responsibility of the management/owner.
9. All the Occupants must know the correct method of operation of the First Aid Fire Fighting System installed.
10. All Security personnel shall be trained to operate the Fire Safety Equipment during the Emergency.
11. This Renewal of Fire No Objection Certificate is valid for one (1) year from the date of issue and it is the responsibility of the builder/occupier to apply for the next Renewal, two months before expiry of this Renewal of Fire NOC.
12. The management instructed to vacate the canteen existing in the cellar .
13. The management instructed to vacate kitchen canteen existing in the cellar with in 3 months .

In view of the above, the **Renewal Fire No Objection Certificate** is Issued for the existing **Non High-Rise Building** consisting of **Cellar + Ground Floor + 4 Upper Floors** at **Meridian School, 8-2-541, Road Number 7, Zahara Nagar, Banjara Hills, Hyderabad, Telangana, PIN 500034, India**, belongs to **Renuka Butta**, subject to compliance of the above terms and conditions.




**Commissioner,
Hyderabad Disaster Response and
Asset Protection Agency.**

Copies to ;

- 1) The management
- 2) The Inspection Committee

This is a computer-generated document and does not require any stamp or signature.




**Principal
Meridian School for Boys and Girls
C.B.S.E. Aff. No.3630044
Road No. 7 Banjara Hills, Hyderabad-3.**

